-P | Heat Transfer

J.-Y. KIM, Hyundai Engineering & Construction, Seoul, Korea, and T.-R. LEE, SK Engineering & Construction Co. Ltd., Seoul, Korea

Performance deterioration by weep hole in a lube oil cooler

The hydrocarbon processing industry (HPI) uses various rotating machines, such as pumps, compressors, blowers and turbines. A rotating machine is normally supplied with a lube oil system: a closedloop system with an oil pump, an oil cooler, a filter, an oil reservoir and other devices, if necessary, as shown in FIG. 1.

A lube oil cooler within the lube oil system is used to eject frictional heat from bearing, jacket, seal devices and other rotation parts. A lube oil cooler is usually a small shell-and-tube type water cooler and is designed with client specifications and/ or in compliance with API standard 614.1 Generally, the Tubular Exchanger Manufacturers Association (TEMA) type for this heat exchanger is AEW or AES.

During normal operation, high alarms of lube oil temperature can be experienced because the lube oil cooler performs insufficiently during the summer season. Normally, the poor performance of a heat exchanger may be caused by one or more of the factors below. However, the poor performance of a small heat exchanger may be caused by others, including:

- High temperature of cooling water
- Low flowrate of cooling water
- Excessive fouling of shell-and-tube heat exchanger
- Tube leakage
- Thermal rating error
- Abnormal process operation.

Weep hole. A weep hole is a small hole on a pass partition plate installed inside the channel of a shell-and-tube heat exchanger. This hole is for complete drainage of the remaining liquid in the tube side, after drainage of liquid from the heat exchanger through the drain nozzle installed at the lowest point of piping. FIG. 2 is the sectional view of a heat exchanger channel and shows weep holes.

This hole is usually a 6-mm diameter hole. Cooling water flows through the front heads (channel) and tubes of the heat exchanger, and gains heat from lube oil while a small amount of cooling water passes a weep hole without heat transfer. In most cases, this cooling water bypass is a very small amount and does not influence exchanger performance. However, this can be important in some cases. A weep hole on the pass partition plate can be the root cause of poor performance of the lube oil cooler, except in the previously mentioned causes.

Description of example case. A blower package manufacturer submitted datasheet and fabrication drawings of a lube oil cooler for review. This lube oil cooler is a TEMA AEU type with cooling water on the tube side and does not consider addition heat transfer area margin. The application of U-tubes in this example is acceptable because the cooling water for this heat exchanger is from a closed-loop




FIG. 1. Simple diagram of lube oil system in a rotating machine.

cooling water system that has low fouling tendency. Weep holes in the drawing were specified as shown in FIG. 2. There was a 6-mm diameter hole on the pass partition plate, which divides the first and fourth tube passes. Additionally, two half holes of 6-mm diameter were specified for complete draining and venting.

The operating condition and geometrical data of the lube oil cooler are summarized in TABLE 1. This information comes from the blower package manufacturer.

Thermal rating and results review.

For performance evaluation of the lube oil cooler, a module of an advanced thermal process design and simulation software^a was used. No critical warning message registered on the software results. The overdesign is 0.23%, and the calculated pressure drops are less than the allowable pressure




FIG. 2. Weep holes in a four-tube-pass shelland-tube heat exchanger.

drops for both shell and tube sides, according to the software results shown in FIG. 3. In addition, this lube oil cooler was properly designed with sealing devices to avoid excessive bypass streams of the shell side.

The overall results of the heat exchanger design seemed to be acceptable, according to the rating result. However, it was noted that the consideration of bypass of cooling water was not made.

	Unit	Hot side	Cold side	
Fluid name	-	Lube oil	Cooling water	
Fluid quantity	kg/hr	3,600	2,447.70	
Temperature, in/out	°C	50 40	32 39	
Inlet pressure	kg ^f /cm ² g	2.472	3.5	
Pressure drop allowance	kgf/cm²	0.3	0.7	
Fouling resistance	m²-hr-°C/kcal	0.0002	0.0002	
Duty	MM kcal/hr	0.0171		
Material	-	Carbon steel	Admiralty	
Design pressure	kg ^f /cm ² g	11	8.5	
Design temperature	°C	90	80	
TEMA type	AEU	Shell ID	154.5 mm	
Tube length	3,600 mm	Number of tubes	33 Us	
Tube OD/Thickness	9.52 mm/1.24 mm	Pitch/pattern	12.693 mm / 30°	
Baffle cut	35.77%	Number of cross passes	36	
Baffle type	single-segment	Baffle orientation	perpendicular	
Baffle center space	92 mm	Impingement	None	
Shell nozzle, in/out	1.5 in./1.5 in.	Tube nozzle, in/out	1.5 in./1.5 in.	
Tube sheet thickness	30 mm	Number of shells	1 series, 1 parallel	
Baffle thickness	6 mm	Sealing parts	1 pairs seal strips 4 x 20-mm seal ro	

TABLE 2. HT	RI result					
Process conditions		Hot s	shell side	Cold tube side		
Fluid name			Lube oil		CW	
Flowrate	1,000 kg/hr		3.6		2.4477	
Inlet/outlet Y	Wt. frac vap.	0	0	0	0	
Inlet/outlet T	°C	50	40	32	39	
Inlet P/avg.	kgf/cm2G	2.472	2.384	3	2.786	
dP/Allow	kgf/cm2	0.175	0.3	0.429	1	
Fouling	m2-hr-C/kcal		0.0002		0.0002	
Exchanger performance						
Shell h	kcal/m²-hr-C	418.99	Actual U	kcal/m²-hr-C	320.19	
Tube h	kcal/m²-hr-C	5383.2	Required U	kcal/m²-hr-C	319.47	
Hot regime		Sens. Liquid	Duty	MM kcal/hr	0.0171	
Cold regime		Sens. liquid	Eff. Area	m²	7.047	
EMTD	°C	7.6	Over-design	%	0.23	
	Shell geometry		Ba	affle geometry		
TEMA type		AEU	Baffle type		Single-seg.	
Shell ID	mm	154.5	Baffle cut	% diameter	35.77	
Series		1	Baffle orientation		Perpend.	
Parallel		1	Central spacing	mm	92	
Orientation	0	0	Crosspasses	·	36	

Flowrate through the weep hole.

What is the flowrate through the weep hole? A flowrate calculation for the orifice can be used to determine the amount of cooling water through the weep hole. The cooling water through the weep hole will be balanced with the cooling water through the tubes by the same pressure drop, as shown in **FIG. 4**.

The flowrate through the weep hole can be calculated with Eq. 1. If a commercial orifice software tool for the orifice is available, it can be used for calculating the flowrate through the weep hole, rather than Eq. 1.

$$Q = C_d A_o Y \sqrt{\frac{2g\Delta P}{\rho(1-\beta^4)}}$$
 (1)

where (TABLE 2):

	Orifice	Weep hole	Unit
Q	Flowrate through orifice	Flowrate through weep hole	m³/sec
C_d	Discharge coefficient	Discharge coefficient	
A_o	Orifice area	Weep hole area	m²
ΔΡ	Orifice pressure drop	Pressure drop through tubes	kg ^f /m ²
g	Gravitational acceleration	Gravitational acceleration	9.8 m/ sec ²
ρ	Density	Density	kg/m³
β	Orifice diameter, pipe diameter	/Weep hole diameter/ channel diameter	
Y	Expansion coefficient	Expansion coefficient	

The parameters of Eq. 1 for the calculation of flowrate through weep hole are defined as:

Discharge coefficient (C_d) is the ratio of the actual discharge to the theoretical discharge and depends on the shape of the orifice. The weep hole is similar to a thin, sharp-edged orifice because pass partition plate thickness is small, compared to the heat exchanger inside diameter. A thin, sharp-edged orifice typically has 0.61 of discharge coefficient.

Expansion coefficient (Y) considers the difference between the discharge coefficient for compressible and incompressible flows. The expansion coefficient for liquid is 1.

Pressure drop through tubes (ΔP) in this result is 0.429 kg^f/cm². This pressure drop includes the pressure drops at nozzles. The pressure drops at inlet and outlet nozzles are 0.003 kg^f/cm² and 0.002 kg^f/

cm², respectively. Therefore, the net pressure drop through tubes is 0.424 kg^f/cm².

Channel diameter (β) is used rather than pipe diameter. Channel diameter is not the exact hydraulic upstream diameter—it can be recognized that the hydraulic upstream diameter of a weep hole is much larger than the weep hole diameter. This means that the β value is slightly affected by the hydraulic upstream diameter. Therefore, the channel diameter is enough to evaluate exchanger performance. Therefore, β will be 0.039 (6 mm divided by 154.6 mm).

Density (average) of cooling water is 991 kg/m^3 .

Evaluation of heat exchanger performance with weep hole consideration.

The flowrate through the weep hole can be 0.000158 m³/sec (563 kg/hr), according to Eq. 1. Therefore, the flowrate through the tubes will be 1,884.7 kg/hr (2,447.7 kg/hr-563 kg/hr). The software^a result of 1,884.7 kg/hr of cooling water flowrate shows that the pressure drop through the tubes is 0.269 kgf/cm2 with an overdesign of -30.1%. It should be noted that

H1		Output Summa Released to the fo		mber Company:		Page '
						Modified MKH units
Rating - Horizonta	l Multipass Flow TEMA AEU Sh	ell With Single-Se	gmental Baffles			
No Data Check Mes	sages. age Report for Warning Messa	noc				
	ress conditions	yes.	Unto	ihell side	Cold tube s	ido
Fluid name	cess conditions		not	Lube oil	Colu tube s	rue CV
Flowrate	(1,000-kg/hr)			3.6000		2.447
Inlet/Outlet Y	(Wt. frac vap.)		0.0000	I 0.0000	0.0000	0.0000
Inlet/Outlet T	(Deg C)		50.00	40.00	32.00	39.0
Inlet P/Avg	(kgf/cm2G)		2.472	2.384	3.000	2.78
dP/Allow	(kgf/cm2)		0.175	0.300	0.429	1.00
Fouling	(m2-hr-C/kcal)			0.000200	•	0.00020
			Exchanger (performance		
Shell h	(kcal/m2-hr-C)		418.99	Actual U	(kcal/m2-hr-C)	320.1
Tube h	(kcal/m2-hr-C)		5383.2	Required U	(kcal/m2-hr-C)	319.4
Hot regime	()		Sens.Liquid	Duty	(MMkcal/hr)	0.017
Cold regime	()		Sens.Liquid	Eff.area	(m2)	7.04
EMTD	(Deg C)		7.6	Over design	(%)	0.2
	Shell geom	etry			Baffle geometry	
TEMA type	()		AEU	Baffle type		Single - Seg
Shell ID	(mm)		154.50	Baffle cut	(Pct Dia.)	35.7
Series	()		1	Baffle orientation	()	Perpend
Parallel	()		1	Central spacing	(mm)	92.00
Orientation	(deg)		0.00	Cross passes	()	3
	Tube geom	etry			Nozzles	
Tube type	()		Plain	Shell inlet	(mm)	33.98
Tube OD	(mm)		9.520	Shell outlet	(mm)	33.98
Length	(mm)		3600	Inlet height	(mm)	17.52
Pitch ratio	()		1.3333	Outlet height	(mm)	17.52
Layout	(deg)		30	Tube inlet	(mm)	33.98
Tube count	()		66	Tube outlet	(mm)	33.98
Tube pass	()		4			
	nal resistance, %		Velocities,		Flow fraction	-
Shell	76.42			in Max	A	0.01
Tube	8.04	Tube side		03 1.04	В	0.60
Fouling	15.06	Cross flow		10 0.33	(0.09
Metal	0.47	Longitudinal	0.	.13 0.24	E	0.22 0.06

FIG. 3. HTRI result.




FIG. 4. Cooling water through weep hole vs. tubes.



SAFE VALVE OPERATION

Electric actuators for all types of industrial valves

Reliable and long-term service. AUMA offers a comprehensive portfolio.

- Customised solutions thanks to the modular scheme
- Corrosion protection with offshore certification
- Temperatures down to -60 °C
- Integration into all conventional distributed control systems
- Worldwide certifications and vendor approvals
- Service worldwide



■ Discover our solutions for the oil and gas industry www.auma.com



outlet temperature Fluid allocation Shell side Tube side

TABLE 3. HTRI input with specifying cooling water flowrate, without specifying

Fluid name	Lube oil		C	:W
Total fluid quantity, 1,000kg/hr	3.6		1.8847	
Temperature, in/out (°C)	50/40		32/Not specified	
Vapor weight fraction, in/out	0	0	0	0
Inlet pressure, kgf/cm²g	2.472		3	
Pressure drop allowance, kgf/cm ²	0.3		1	
Min. fouling resistance, m²-hr-°C/kcal	0.0002		0.0002	

TABLE 4. Exchanger performance evaluation through iterations						
	1st	2nd	3rd	4th	5th	
Flowrate through weep hole, kg/hr	0	563	446	471	466	
Flowrate through tubes, kg/hr	2,447.70	1,884.70	2,001.70	1,976.70	1,981.70	
Total pressure drop, kgf/cm²	0.429	0.269	0.299	0.293	0.293	
MTD, °C	7.6	5.3	6	5.9	5.9	
Over-design	0.23%	-30.10%	-22.10%	-23.90%	-23.90%	

TABLE 5. Exchanger performance for improved design					
	1st	2nd	3rd		
Flowrate through weep hole, kg/hr	0	287	262		
Flowrate through tubes, kg/hr	2,856.60	2568.6	2594.6		
Total pressure drop, kgf/cm²	0.564	0.467	0.475		
MTD, °C	8.4	7.9	7.9		
Over-design	11.50%	4.10%	4.90%		

the outlet temperature of cooling water is not specified on HTRI input as shown in **TABLE 3.** The two half weep holes can be ignored, because the calculated flowrate through half weep holes is relatively small, comparing the full diameter weep hole on the pass partition plate which divides the first and fourth tube pass.

The flowrate through the weep hole should be calculated again with the new pressure drop of tubes, 0.269 kg^f/ cm². The flowrate through tubes will be changed to 2,001.4 kg/hr, and the pressure drop through tubes will be 0.299 kgf/cm2 with -22.0% of over-design. After several iterations, the mean temperature difference (MTD) will be converged, as shown in TABLE 4. Final performance evaluation shows that the over-design is -23.9% with a warning message showing that an "internal temperature cross exists in the exchanger" in the program result. The main reason for poor performance is due to lower MTD, rather than design. In addition, this lube oil cooler has no

design margin, and potential low performance of this cooler is expected during summer season. In this example, the module of the advanced thermal process design and simulation software^a was used for thermal rating. The software tools for heat exchanger design other than the module of the proprietary software can be used with the same concept.

Solution. To improve the lube oil cooler, performance evaluations have been performed with a smaller-diameter weep hole and more cooling water, as shown in **TABLE 5**, because both are simple to change without heat exchanger design. The weep hole size has been adjusted from 6 mm to 4 mm, which reduces the weep hole area by 56%. The cooling water flowrate has been increased from 2,447.7 kg/hr to 2,856.6 kg/hr, which is only a 409-kg/hr increase. The over-design is 4.9%, with consideration of cooling water bypass. Additionally, no warning message exists regarding temperature cross in the software result.

This evaluation and design improvements have been shared with a process engineer and a blower package manufacturer. A process engineer confirmed that the increased cooling water can be accommodated, and the blower package manufacturer agreed with reducing weep hole size.

Takeaway. In the example case, a small amount of cooling water passing a weep hole can have an effect on the performance of a lube oil cooler. The performance effect of weep hole size also depends on heat exchanger service. It is suggested that a performance evaluation that considers weep holes should be considered if a heat exchanger has two or more of the features here:

- Small cooling water flowrate in the tube side
- · Operating condition causing low MTD
- Small heat exchanger
- · Low heat transfer rate in the tube side.

In addition, it is recommended that an additional surface margin be added, because this kind of heat exchanger is small, and two or three tubes can provide the ample surface margin with additional low cost. HP

NOTES

^a HTRI Xchanger Suite

LITERATURE CITED

¹ American Petroleum Institute, "API standard 614.1—Lubrication shaft-sealing and oil-control systems and auxiliaries," 5th Ed., April 2008.



JU-YOUNG KIM works as a Heat Transfer Engineer at Hyundai Engineering & Construction in Seoul, Korea, after working as a process and heat transfer engineer at SK Engineering & Construction and Hyundai Heavy

Industries. He has more than 25 yr of experience in process and heat transfer engineering for refinery and petrochemical plants and gas treatment plants. From 2013-2015, he served as a Chairman on the Korea Communication Committee of HTRI. Mr. Kim earned a BS degree in chemical engineering from the University of Seoul.



TAIK-RYOUL LEE is a Senior Manager of oil and gas process engineering for SK Engineering & Construction Co. Ltd. in Seoul, Korea. He manages the process engineering department to implement feasibility studies.

conceptual engineering, FEED and EPC projects. He has more than 25 yr of experience in the design and engineering of plants in the oil and gas, petrochemical, LNG, chemical and power sectors.